



State of New Jersey  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
reMail Code 401-04Q

PHILIP D. MURPHY  
GOVERNOR

TAHESHA L. WAY  
LT. GOVERNOR

Division of Water Supply & Geoscience  
Water System Operations Element  
Bureau of Water System Engineering  
401 E. State Street - P.O. Box 420  
Trenton, New Jersey 08625-0420  
Tel #: (609) 292-2957 - Fax #: (609) 292-1654  
<http://www.nj.gov/dep/watersupply/>

SHAWN LATOURETTE  
COMMISSIONER

CCR Year: 2024  
(2023 data)

### 2024 Consumer Confidence Report (CCR) Certification Form

PWS ID# NJ 0108009

Community Water System Name: Stoney Field MHP

Community Water System Address: 1059 Ocean Heights Avenue, Egg Harbor Twp, NJ 08234

1. CCRs must be mailed or electronically delivered to all bill-paying customers by July 1<sup>st</sup>. Provide date(s) of distribution: \_\_\_\_\_
2. Please check the distribution method(s) utilized to reach your bill-paying customers.
  - Mailed the CCR
  - Mailed the direct URL of the CCR
  - Embedded in an email message
  - Attached as a PDF file in an email message
  - Provided the website link (URL) in an email message
  - Provided information on how a hardcopy of the CCR can be obtained
3. If the CCR was provided to customers electronically, provide the direct URL:  
\_\_\_\_\_
4. Community Water Systems serving greater than or equal to 100,000 persons must post their CCR on the Internet. Date posted on the Internet *and* the URL: N/A
5. Community Water Systems must make a good faith effort to reach all appropriate non-bill paying customers. Check all of the methods that were utilized by your community water system.
  - Posted the CCR on the Internet at www.\_\_\_\_\_
  - Mailed the CCR to postal patrons within the service area (attach a list of zip codes used)
  - Advertised availability of the CCR in news media (attach copy of announcement)
  - Published CCR in local newspaper (attach copy of newspaper announcement)

- Posted the CCR in public places (attach a list of locations)
- Delivered multiple copies to single bill addresses serving several persons such as: apartments, businesses, and large private employers
- Delivered copy of the CCR to community organizations (attach a list)
- Electronic city newsletter or electronic community newsletter or listserv (attach a copy of the article or notice)
- Electronic announcement of CCR availability via social media outlets (attach list of social media outlets utilized)
- Other (List): \_\_\_\_\_

6. If your Community Water System sells water to another Community Water System, list the name and PWSID Number of the Community Water System(s) and the date the information was provided (due no later than April 1<sup>st</sup> unless mutually agreed upon by both systems): N/A
7. Is the CCR being utilized to satisfy a Public Notice requirement pertaining to N.J.A.C. 7:10-7.4 for iron, manganese, or sodium?  Yes  No (check one)
8. Is the CCR being utilized to satisfy a Tier 3 Public Notice requirement?  Yes  No (check one)

NOTE: If you checked "Yes":

1. Submit the PN Certification Form for any Tier 3 PN requirement not previously submitted to DEP.
2. Include the necessary standard language for a reporting violation, found at 40 CFR 141.205(d).

9. Check all distribution method(s) for the submittal to the Bureau of Safe Drinking Water (Bureau)\*\*.

- Attached as a PDF file in an email message to watersupply@dep.nj.gov **(this method is preferred)\*\***
- Provided the website link (URL) in an email message to watersupply@dep.nj.gov
- Mailed the CCR\*\* (see note below)

**\*\*IMPORTANT\*\*** Note that a non-submittal or late submittal of the CCR and/or Certification to the Bureau will result in a reporting violation. As such, we strongly recommend that you submit a copy using a means that can document the date of Bureau receipt, such as by email (watersupply@dep.nj.gov) or by Certified mail.

10. The Certification below must be completed by the Community Water System.

I certify that the above referenced community water system has distributed the CCR in accordance with all applicable regulations. Furthermore, I certify that the information contained in the report is correct and consistent with the compliance monitoring data previously submitted to the state.

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Print Name: \_\_\_\_\_ Title: \_\_\_\_\_

PWSID #: NJ0108009 Water System Name: Stoney Field MHP

Email : \_\_\_\_\_ Phone Number: \_\_\_\_\_



**Annual Drinking Water Quality Report  
Stoney Field Mobile Home Park  
PWSID# NJ0108009  
For the Year 2024, Results from the Year 2023**

Stoney Field Mobile Home Park is pleased to present to you this year's Annual Drinking Water Quality Report. Our drinking water is pumped from 2 active wells on site in Atlantic County.

*Landlords must distribute this information to every tenant as soon as practicable, but no later than three business days after receipt. Delivery must be done by hand, mail, or email, and by posting the information in a prominent location at the entrance of each rental premises, pursuant to section 3 of P.L. 2021, c. 82 (C.58:12A-12.4 et seq.).*

Call us at (609)646-6788 to find out how to get your water tested for lead. Testing is essential because you cannot see, taste, or smell lead in drinking water.

Stoney Field Mobile Home Park routinely monitors for contaminants in your drinking water according to Federal and State laws. This table shows the test results of our monitoring for the period of January 1<sup>st</sup> to December 31<sup>st</sup>, 2023. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our test results, though representative, are more than one year old and are the most recent results available.

**Vulnerable Populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

TABLE OF DETECTED CONTAMINANTS						
Contaminant	Violation Y/N	Level Detected	Units of Measure ment	MC LG	MCL	Likely Source of Contamination
<b>Inorganic Contaminants</b>						
Barium Test Results Yr.: 2021	N	0.072	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Chromium Test Results Yr.: 2021	N	0.811	ppb	100	100	Discharge from steel and pulp mills; erosion of natural deposits
Lead Result at 90th Percentile	N	3.17 No samples exceeded AL	ppb	0	AL=15	Corrosion of household plumbing systems, erosion of natural deposits
Mercury (inorganic) Test Results Yr.: 2021	N	1.11	ppb	2	2	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
Nickel Test Results Yr.: 2021	N	3.21	ppb	n/a	n/a	Erosion of natural deposits
Nitrate (as Nitrogen)	N	2.21	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Volatile Organic Contaminants</b>						
MTBE Methyl tert butyl ether	N	0.9	ppb	0	70	Leaking underground and above ground fuel storage tanks, pipelines and refueling spills.
Naphthalene	N		ppb	0	300	Discharge from factories; leaching from fuel storage tanks and landfills.

TABLE OF DETECTED CONTAMINANTS						
Contaminant	Violation Y/N	Level Detected	Units of Measurement	MC LG	MCL	Likely Source of Contamination
<b>PFAS Per- and Polyfluoroalkyl Substances</b>						
PFOA Perfluorooctanoic Acid	N	4.72	ppt	n/a	14	Discharge from industrial, chemical, and manufacturing factories, release of aqueous film forming foam.
<b>Disinfection By-products</b>						
TTHM Total Trihalomethanes	N	1.89	ppb	n/a	80	By-product of drinking water disinfection

Regulated Disinfectants	Violation Y/N	Level Detected (Average, Lowest & Highest Detect)	Units of Measurement	MRDL	MRDLG	Typical Source
Chlorine	N	Average = 0.53 Lowest = 0.00 Highest = 0.88	ppm	4.0	4.0	Water additive used to control microbes

**Monitoring Violation:** This past year, Stoney Field Mobile Home Park incurred a Monitoring and Reporting Violation of the Lead and Copper Rule (LCR) for failure to submit all Water Quality Parameter results from the month of May 2023. The samples were collected, analyzed, and submitted on time. We believe this violation is in error and we requested that it be removed from the NJDEP system on November 8, 2023.

**Potential Sources of Contamination:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water, which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Stoney Field Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### DEFINITIONS

In the "TABLE OF DETECTED CONTAMINANTS" you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

**Non-Detects (ND)** - laboratory analysis indicates that the constituent is not present.

**Parts per million (ppm) or Milligrams per liter (mg/l)** - one part per million corresponds to one minute in two years or a single penny in \$10,000.

**Parts per billion (ppb) or Micrograms per liter** - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

**Parts per trillion (ppt) or Nanograms per liter (nanograms/l)** - one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000

**Picocuries per liter (pCi/L)** - Picocuries per liter is a measure of the radioactivity in water.

**Treatment Technique (TT)** - A required process intended to reduce the level of a contaminant in drinking water.

**Action Level (AL)** - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level** - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

**Maximum Contaminant Level Goal** -The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Secondary Contaminant** - Substances that do not have an impact on health. Secondary Contaminants affect aesthetic qualities such as odor, taste or appearance. Secondary standards are recommendations, not mandates.

**Recommended Upper Limit (RUL)** – Recommended maximum concentration of secondary contaminants. These reflect aesthetic qualities such as odor, taste or appearance. RULs are recommendations, not mandates.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Goal (MRDLG):** The level of a drinking water disinfectant, below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination

**Waivers:** The Safe Drinking Water Act regulations allow monitoring waivers to reduce or eliminate the monitoring requirements for asbestos, volatile organic chemicals and synthetic organic chemicals. Our system received a monitoring waiver for asbestos and received a waiver for synthetic organic chemicals (SOC) for the previous waiver period. We have applied for and expect to receive a SOC waiver for the current waiver period upon NJDEP approval.

**For Additional Information:** If you have any questions about this report or concerning your water quality, please contact Stoney Field Mobile Home Park at (609)646-6788 because we do not hold regular public meetings. We want our valued customers to be informed about their water quality.

**Source Water Assessment:** The New Jersey Department of Environmental Protection (NJDEP) has completed and issued the Source Water Assessment Report and Summary for this public water system, which is available at <http://www.nj.gov/dep/watersupply/swap/index.html>, or by contacting the NJDEP, Bureau of Safe Drinking Water at 609-292-5550 or [watersupply@dep.nj.gov](mailto:watersupply@dep.nj.gov).

**Susceptibility Ratings for Stoney Field Mobile Home Park Sources**

The table below illustrates the susceptibility ratings for the seven contaminant categories (and radon) for each source in the system. The table provides the number of wells and intakes that rated high (H), medium (M), or low (L) for each contaminant category. For susceptibility ratings of purchased water, refer to the specific water system’s source water assessment report.

The seven contaminant categories are defined at the bottom of this page. DEP considered all surface water highly susceptible to pathogens, therefore all intakes received a high rating for the pathogen category. For the purpose of Source Water Assessment Program, radionuclides are more of a concern for ground water than surface water. As a result, surface water intakes’ susceptibility to radionuclides was not determined and they all received a low rating.

**If a system is rated highly susceptible for a contaminant category, it does not mean a customer is or will be consuming contaminated drinking water.** The rating reflects the potential for contamination of source water, not the existence of contamination. Public water systems are required to monitor for regulated contaminants and to install treatment if any contaminants are detected at frequencies and concentrations above allowable levels. As a result of the assessments, DEP may customize (change existing) monitoring schedules based on the susceptibility ratings.

Sources	Pathogens			Nutrients			Pesticides			Volatile Organic Compounds			Inorganics			Radio-nuclides			Radon			Disinfection Byproduct Precursors			
	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	H	M	L	
Wells - 2		1	1	2				1	1			2		1	1	2				2			2		

**Pathogens:** Disease-causing organisms such as bacteria and viruses. Common sources are animal and human fecal wastes.

**Nutrients:** Compounds, minerals and elements that aid growth, that are both naturally occurring and man-made. Examples include nitrogen and phosphorus.

**Volatile Organic Compounds:** Man-made chemicals used as solvents, degreasers, and gasoline components. Examples include benzene, methyl tertiary butyl ether (MTBE), and vinyl chloride.

**Pesticides:** Man-made chemicals used to control pests, weeds and fungus. Common sources include land application and manufacturing centers of pesticides. Examples include herbicides such as atrazine, and insecticides such as chlordane.

**Inorganics:** Mineral-based compounds that are both naturally occurring and man-made. Examples include arsenic, asbestos, copper, lead, and nitrate.

**Radionuclides:** Radioactive substances that are both naturally occurring and man-made. Examples include radium and uranium.

**Radon:** Colorless, odorless, cancer-causing gas that occurs naturally in the environment. For more information go to <http://www.nj.gov/dep/rpp/radon/index.htm> or call (800) 648-0394.

**Disinfection Byproduct Precursors:** A common source is naturally occurring organic matter in surface water. Disinfection byproducts are formed when the disinfectants (usually chlorine) used to kill pathogens react with dissolved organic material (for example leaves) present in surface water.